



MCWAP-2A CONTRACT No TCTA 20-041

**RECORD OF MEETING/DISCUSSION/ACTION LIST**

Date: 30/08/2023 Location: Webmeeting File No: 01/02/04/  
 Time: 11:20 – 13:50am

<b>Subject</b> :	<b>MOKOLO AND CROCODILE RIVER (WEST) WATER AUGMENTATION PROJECT (PHASE 2A) (MCWAP-2A): HLRM RE-ROUTING ESKOM MEETING</b>	
<b>Present</b> :	Alan Bosman (AB)	Eskom (Land Portfolio)
	Micheal Taffa (MT)	Eskom (Land Portfolio)
	Deon Erstehuizen (DE)	GBN-JV
	Umeshree Naicker (UN)	GBN-JV
	Minenhle Luthuli (ML)	GBN-JV
<b>Distribution</b> :	All present	

Description:	By	Action
<b>1. WELCOME AND INTRODUCTION</b>		
<p>DE welcomed and acknowledged all present and requested introductions around the virtual table.</p> <p>MT introduced himself and AB indicating that they are in the Eskom's Generation, Transmission and Distribution land portfolio department. He advised that the land in question (Paarl 124 KQ portion 7) was bought for Eskom Transmission.</p>		
<b>2. HIGH LIFT RAISING MAIN DEVIATIONS</b>		
<p>DE presented the alternative pipeline options for the project and explained that is due to the objections from Eskom, which would deviate from the authorized environmental authorization and Eskom's power lines.</p> <p>DE indicated that there are three (3) proposed routes alternatives. There's a Western alternative, which is shown in red in the map the Eastern alternative, which is shown in green, and we've also considered a Sub Alternative to the Eastern Alternative, which is a blue box (refer to map in Annexure A).</p> <p>DE advised that the Western Alternative still crosses the transmission lines twice. He indicated that the Eastern Alternative doesn't cross the transmission lines, but the GBN-JV would need to understand Eskom future developments. The Eastern Alternative bypasses the farmhouse. To avoid the farmhouse a Sub Alternative to the Eastern Alternative has been created.</p>		
<b>3. ESKOM REQUIREMENTS</b>		
<p>MT and AB advised that the Eastern alternative with the Sub Alternative to avoid the farmhouse is the preferred alternative.</p> <p>DE asked if the Western alternative would be considered by Eskom. AB indicated that the Eskom Transmission Team would need to advise fully but from his understanding because this is pressure</p>		GBN-JV to meet with the Transmission

<p>pump pipeline and not a gravitational pipeline, the water might be close enough to cause a trip causing catastrophic failure.</p>		<p>Team for their comment.</p>
<p><b>4. <u>WAYFORWARD</u></b></p>		
<ul style="list-style-type: none"> <li>• DE advised that the Basic Assessment Report will be circulated for Eskom's formal comments.</li> </ul> <p>The GBN-JV will invite the Eskom Transmission Team to discuss Eskom requirements.</p>		